



**STATE OF CONNECTICUT
DEPARTMENT OF TRANSPORTATION**

**2800 BERLIN TURNPIKE, P.O. BOX 317546
NEWINGTON, CONNECTICUT 06131-7546**



Phone: 860-594-3128

August 25, 2016

Subject: Project No. 63-704

F.A.P. No. 6063(007)

Rehabilitation of Bridge No. 00481 Airport Road over Route 15.

NOTICE TO CONTRACTORS:

This is to notify all concerned and especially the prospective bidders that the bid opening for the subject project is previously postponed from August 24, 2016 to August 31, 2016 at 2:00 P.M. in the Conference Room of the Department of Transportation Administration Building, 2800 Berlin Turnpike, Newington, Connecticut.

Addendum No. 1 is attached and can also be obtained on the Statewide Contracting Portal at http://www.biznet.ct.gov/scp_search/BidResults.aspx?groupid=64

This addendum is necessary to add a new special provision, add new contract items, revise contract items and revise plan sheets.

Bid Proposal Forms (0063-0704.EBS file and amendment file 0063-0704.00# if applicable) are available for those bidders that have received approval from the Department to bid on the subject project.

Pre-Bid Questions and Answers: Questions pertaining to DOT advertised construction projects must be presented through the CTDOT Pre-Bid Q and A Website. The Department cannot guarantee that all questions will be answered prior to the bid date. **PLEASE NOTE - at 12:01 am, the day before the bid, the subject project(s) being bid will be removed from the Q and A Website, Projects Advertised Section, at which time questions can no longer be submitted through the Q and A Website. At this time, the Q and A for those projects will be considered final, unless otherwise stated and/or the bid is postponed to a future date and time to allow for further questions and answers to be posted.**

H. J. Emond

For: Gregory D. Straka

Contracts Manager

Division of Contracts Administration

AUGUST 22, 2016
REHABILITATION OF BRIDGE NO. 00481,
AIRPORT ROAD OVER ROUTE 15 (WILBUR CROSS HIGHWAY)
FEDERAL AID PROJECT NO. 6063(007)
STATE PROJECT NO. 63-704
CITY OF HARTFORD

ADDENDUM NO. 1

This Addendum addresses the following questions and answers contained on the “CT DOT QUESTIONS AND ANSWERS WEBSITE FOR ADVERTISED CONSTRUCTION PROJECTS”:

Question and Answer No. 2.

SPECIAL PROVISION
NEW SPECIAL PROVISION

The following Special Provision is hereby added to the Contract:

- **NOTICE TO CONTRACTOR – MINIMUM CONCRETE COMPRESSIVE STRENGTH**

CONTRACT ITEMS
NEW CONTRACT ITEMS

<u>ITEM NO.</u>	<u>DESCRIPTION</u>	<u>UNIT</u>	<u>QUANTITY</u>
<u>0944000</u>	<u>FURNISHING AND PLACING TOPSOIL</u>	<u>SY</u>	<u>140</u>
<u>0950005</u>	<u>TURF ESTABLISHMENT</u>	<u>SY</u>	<u>140</u>

REVISED CONTRACT ITEMS

<u>ITEM NO.</u>	<u>DESCRIPTION</u>	<u>ORIGINAL QUANTITY</u>	<u>REVISED QUANTITY</u>
<u>0202529</u>	<u>CUT BITUMINOUS CONCRETE PAVEMENT</u>	<u>1290 LF</u>	<u>1900 LF</u>
<u>0305001</u>	<u>PROCESSED AGGREGATE</u>	<u>187 CY</u>	<u>220 CY</u>
<u>0406159</u>	<u>PMA S0.5</u>	<u>637 TON</u>	<u>685 TON</u>

PLANS

REVISED PLANS

The following Plan Sheets are hereby deleted and replaced with the like-numbered Plan Sheets:

02.01.A1

03.02.A1

The Detailed Estimate Sheets do not reflect these changes.

The Bid Proposal Form has been revised to reflect these changes.

There will be no change in the number of calendar days due to this Addendum.

The foregoing is hereby made a part of the contract.

NOTICE TO CONTRACTOR – MINIMUM CONCRETE COMPRESSIVE STRENGTH

The concrete strength or allowable design stress specified in the General Notes is for design purposes only. The minimum compressive strength of concrete in constructed components shall comply with the requirements of Section 6.01 Concrete for Structures.